

To,

The Principal,

Holy Heart School,
Ajitwal, Distt Moga (Punjab) ।

ਨੰਬਰ 163

ਮਿਤੀ 05/04/2026


ਵਿਸ਼ਾ:

ਇਮਾਰਤ ਸੁਰੱਖਿਅਤ ਹੋਣ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ ਬਾਬਤ 2026-27 ।

ਉਪਰੋਕਤ ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਦਾ ਨਿਰੀਖਣ ਸਬੰਧਤ ਜੂਨੀਅਰ ਇੰਜਨੀਅਰ ਵਲੋਂ ਕੀਤਾ ਗਿਆ । ਬਿਲਡਿੰਗ 2026-27 ਲਈ ਸੁਰੱਖਿਅਤ ਪਾਈ ਗਈ ਹੈ । ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਸੁਰੱਖਿਅਤ ਹੋਣ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ ਆਪ ਨੂੰ ਮਿਤੀ 31-03-2027 ਤੱਕ ਜਾਰੀ ਕੀਤਾ ਗਿਆ ਹੈ । ਅੱਗੇ ਤੋਂ ਹੇਠ ਲਿਖੀਆਂ ਹਦਾਇਤਾਂ ਵਲੋਂ ਵਿਸ਼ੇਸ਼ ਧਿਆਨ ਦਿੱਤਾ ਜਾਵੇ ।

- 1) ਬਿਲਡਿੰਗ ਦੇ ਆਲੇ-ਦੁਆਲੇ ਅਤੇ ਛੱਤਾ ਉਪਰ ਪਾਣੀ ਨਾ ਖੜਾ ਹੋਣ ਦਿੱਤਾ ਜਾਵੇ।
- 2) ਜੇਕਰ ਬਿਲਡਿੰਗ ਵਿਚ ਕਿਸੇ ਕਿਸਮ ਦੀ ਤਰੇੜ ਆ ਜਾਦੀ ਹੈ ਤਾਂ ਉਸ ਜਗ੍ਹਾ ਨੂੰ ਤੁਰੰਤ ਖਾਲੀ ਕੀਤਾ ਜਾਵੇ ਤੇ ਉਸ ਦੀ ਤੁਰੰਤ ਰਿਪੋਅਰ ਕਰਵਾਈ ਜਾਵੇ ।
- 3) ਕਿਸੇ ਕਿਸਮ ਦੀ ਉਸਾਰੀ ਵਿਚ ਵਰਤੇ ਗਏ ਮਟੀਰੀਅਲ ਦੀ ਜ਼ਿੰਮੇਵਾਰੀ ਸਬੰਧਤ ਸਕੂਲ ਦੀ ਹੋਵੇਗੀ । ਆਪ ਵਲੋਂ ਨੱਥੀ ਨਕਸ਼ੇ ਤੋਂ ਇਲਾਵਾ ਜੇਕਰ ਆਪ ਵਲੋਂ ਵਾਧੂ ਉਸਾਰੀ ਕਰਨੀ ਹੋਵੇ ਤਾਂ ਉਸ ਦੀ ਮੰਨਜ਼ੂਰੀ ਮਹਿਕਮੇ ਵਲੋਂ ਲਈ ਜਾਵੇਗੀ ।
- 4) ਡਾਇਰੈਕਟਰ ਜਨਰਲ ਸਕੂਲ ਸਿੱਖਿਆ ਵਿਭਾਗ ਪੰਜਾਬ ਅਤੇ ਸਟੇਟ ਪ੍ਰੋਜੈਕਟ ਸਰਵ ਸਿੱਖਿਆ ਅਭਿਆਨ ਦੇ ਪੱਤਰ ਨੰਬਰ 75444 ਮਿਤੀ 06-11-2009 ਮੁਤਾਬਿਕ ਸਕੂਲ ਵਿਚ ਅੱਗ ਬੁਝਾਓ ਯੰਤਰ ਠੀਕ ਹਾਲਤ ਵਿਚ ਰੱਖੇ ਜਾਣ । ਕਿਸੇ ਵੀ ਅਣਸੁਖਾਵੀ ਘਟਨਾ ਦੀ ਜ਼ਿੰਮੇਵਾਰੀ ਸਬੰਧਤ ਸਕੂਲ ਦੀ ਹੋਵੇਗੀ ।
- 5) ਅਗਲੇ ਸਾਲ 2027-28 ਦੀ ਇੰਨਸਪੈਕਸ਼ਨ ਕਰਾਉਣੀ ਯਕੀਨੀ ਬਣਾਈ ਜਾਵੇ ।

ਨੱਥੀ ਸਰਟੀਫਿਕੇਟ,


ਉਪ ਮੰਡਲ ਇੰਜਨੀਅਰ,
ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਨੰ. ਭ.ਮ. ਸਾਖਾ,
ਮੋਗਾ ।

PROFORMA FOR SAFETY OF SCHOOL BUILDING

PART-I

(To be filled by the Head of School / Institute)

- 1) Name of the School **HOLY HEART SCHOOL**
- 2) Location **AJITWAL MOGA**
- 3) Plot Area.
- 4) Plinth Area. **GF 7150 SF, FF, 3978 SF**
- 5) Number of storey's **TWO**
- 6) Year of construction of Building **2004, 2005, 2009**
- 7) If the building has been constructed under the Supervision of the qualified Engineer, the following details may be given:-
 - a) Name of the Engineer with Qualification. :
 - b) Address of Engineer. :
 - c) Set of structural drawing used in the construction, Available. :
 - d) Name & address of Architect with qualification :
- 8) Whether the building has been constructed for the Purpose school. : ☒ Yes / No
 Residential purpose and converted for use as a school : ☐ Yes / No
- 9) Material used for Roof.
 - a) R.C.C slab/ R.B.C Slabs : ☒ Yes / No
 - b) R.S. Joist & Battens. : ☐ Yes / No
 - c) Wooden Joist & Battens : ☐ Yes / No.
- 10) Material used for walls.
 - a) Mud Mortar. : ☒ Yes / No
 - b) Cement Mortar. : ☐ Yes / No
 - c) Lime Mortar. : ☐ Yes / No
- 11) Flooring.
 - a) Conglomerate : ☐ Yes / No
 - b) Terrazzo. : ☒ Yes / No
 - c) Brick Paving : ☐ Yes / No
- 12) A detailed drawing indicating dimension of Room Alongwith size and location of doors and windows (attached).
- 13) For Fire Safety.
 - a) Weather the width of the staircase is 1.5 Mtr. : ☒ Yes / No
 - b) Weather portable fire exiting. : ☐ Yes / No
 - c) Weather School building is free from inflammable & toxic material : ☐ Yes / No
 - d) Weather Cooking of food is done at a safe place : ☐ Yes / No
 - e) Weather any thatch of combustibile material as been Used. : ☐ Yes / No

14) Requirement for fire Protection Arrangements under NBC
Part -IV

- (For Building height Less than 15metre)
- | | |
|--|----------|
| a) Weather house Real provided. | Yes / No |
| b) Weather down corner provided. | Yes / No |
| c) Weather automatic sprinkler provided. | Yes / No |
| d) Weather underground static water storage tank of Capacity 50,000Ltr. (It converted are excess 1600sqm) | Yes / No |
| e) Weather over head tank of capacity 10,000 Ltr. Exists. (in case of house real) 20,000 Ltr. | Yes/ No |
| f) Weather one electric and one diesel pump of 3 kg/ cum Pressure of capacity 1620 LPM. One electric pump of Capacity 180LPM exist near underground static tank. | Yes/No |
| g) Weather a pump 3 Kg /cum preasur& 450/500 LPM Exist near over head tank. | Yes/ No |

[Signature]
Principal
HOLY HEART SCHOOL
Ajitwal (Moga)

PART -II

(To be filled by the S.D.E for PWD (B&R) Department)

- a) I have visited the above mentioned school on date 03/04/2026 And have been visually inspected it from all angles of safety and fined it fit for normal used as school buildings.
- b) In case and addition / alteration of expansion and modifications to this building is to be carried out the same be carried out under the supervision of a qualification Engineer and this certificate may be re-obtained after the completion from the undersigned.
- c) In case the building is affected by food , or if there is settlement of walls/ foundation of sagging of roofs etc. immediate inspection of the undersigned by arranged to check the stability and safety of the building.
- d) This building can be safety occupied for normal used upto (indicate upto which it can be used) one years only (31/03) 2027

[Signature]
S.D.E for PWD (B&R)
Moga